

CERTIFICATE OF ANALYSIS

Work Order : **EW2004977**
Client : **MERRY BEACH CARAVAN PARK**
Contact : **MANAGER (REPORTS AND INVOICES)**
Address : **Merry Beach Rd**
Kioloa NSW 2539

Telephone : ----
Project : **Merry Beach Monitoring**
Order number : **P1806838**
C-O-C number : ----
Sampler : **Peter Young**
Site : **Merry Beach**
Quote number : **WO/010/16**
No. of samples received : **6**
No. of samples analysed : **6**

Page : 1 of 4
Laboratory : **Environmental Division NSW South Coast**
Contact : **Glenn Davies**
Address : **1/19 Ralph Black Dr, North Wollongong 2500**
4/13 Geary Pl, North Nowra 2541
Australia NSW Australia
Telephone : **+61 2 4225 3125**
Date Samples Received : **03-Nov-2020 15:43**
Date Analysis Commenced : **04-Nov-2020**
Issue Date : **10-Nov-2020 15:40**



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Clare Kennedy	Analyst	Inorganics, Fyshwick, ACT
Somlok Chai	Microbiologist	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- **Analytical work for this work order will be conducted at ALS Sydney.**
- MF = membrane filtration
- CFU = colony forming unit
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 - 100cfu.
- MW023 is ALS's internal code and is equivalent to AS4276.9.
- MW006 is ALS's internal code and is equivalent to AS4276.7.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Client sample ID			884/Eff1	884/Eff2	884/SW1	884/SW2	884/SW3	
Client sampling date / time		03-Nov-2020 10:40			03-Nov-2020 10:45		03-Nov-2020 10:20		03-Nov-2020 10:35	
Compound	CAS Number	LOR	Unit	EW2004977-001	EW2004977-002	EW2004977-003	EW2004977-004	EW2004977-005		
				Result	Result	Result	Result	Result		
EA005P: pH by PC Titrator										
pH Value	----	0.01	pH Unit	7.85	8.08	6.88	6.92	7.48		
EA010P: Conductivity by PC Titrator										
Electrical Conductivity @ 25°C	----	1	µS/cm	----	----	821	998	2640		
EA025: Suspended Solids										
Suspended Solids (SS)	----	5	mg/L	----	8	----	----	----		
EA025: Total Suspended Solids dried at 104 ± 2°C										
Suspended Solids (SS)	----	5	mg/L	10	----	----	----	----		
EK055G: Ammonia as N by Discrete Analyser										
Ammonia as N	7664-41-7	0.01	mg/L	<0.01	----	<0.01	0.10	0.34		
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser										
Nitrite + Nitrate as N	----	0.01	mg/L	14.3	----	0.02	0.28	0.08		
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser										
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	4.0	----	0.8	0.8	2.0		
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser										
^ Total Nitrogen as N	----	0.1	mg/L	18.3	----	----	----	----		
EK067G: Total Phosphorus as P by Discrete Analyser										
Total Phosphorus as P	----	0.01	mg/L	9.57	----	0.03	0.06	0.35		
EP020: Oil and Grease (O&G)										
Oil and Grease	----	1	mg/L	<1	----	----	----	----		
EP030: Biochemical Oxygen Demand (BOD)										
Biochemical Oxygen Demand	----	2	mg/L	<2	----	<2	<2	3		
MW006: Faecal Coliforms & E.coli by MF										
Faecal Coliforms	----	1	CFU/100mL	<1	----	410	~110	2400		
<i>Escherichia coli</i>	----	1	CFU/100mL	----	<1	----	----	----		
MW023: Enterococci by Membrane Filtration										
Enterococci	----	1	CFU/100mL	----	----	70	500	510		



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Client sample ID		Influent	----	----	----	----
Client sampling date / time		03-Nov-2020 10:47		----	----	----	----	----
Compound	CAS Number	LOR	Unit	EW2004977-006	-----	-----	-----	-----
				Result	----	----	----	----
EA005P: pH by PC Titrator								
pH Value	----	0.01	pH Unit	8.00	----	----	----	----
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)	----	5	mg/L	2460	----	----	----	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	12.8	----	----	----	----
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Nitrite + Nitrate as N	----	0.01	mg/L	0.12	----	----	----	----
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	150	----	----	----	----
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser								
^ Total Nitrogen as N	----	0.1	mg/L	150	----	----	----	----
EK067G: Total Phosphorus as P by Discrete Analyser								
Total Phosphorus as P	----	0.01	mg/L	104	----	----	----	----
EP020: Oil and Grease (O&G)								
Oil and Grease	----	1	mg/L	<1	----	----	----	----
EP030: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	95	----	----	----	----
MW006: Faecal Coliforms & E.coli by MF								
Faecal Coliforms	----	1	CFU/100mL	520000	----	----	----	----
<i>Escherichia coli</i>	----	1	CFU/100mL	520000	----	----	----	----